

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0028:221 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Notifier, One Fire-Lite Place, Northford CT 06472-1653
Contact: Larry Flood (203) 484-1200 Fax (203) 484-7309

DESIGN: Models NCS-F-ONYX and NCS-W-ONYX Network Control Stations. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Primary operating supply – 120 V ac, 60 Hz, 6 A Maximum
240 V ac, 50 Hz, 3 A Maximum

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, UL label and reference to the installation instructions Part No. 51585, Revision A: Part No. 51658, Revision A.

SPECIAL MARKING: Each unit shall be marked with the following or equivalent statement: "Suitable For Installation As A Style 4, 7 Proprietary Multiplex System Or Type 3 Central Station Multiplex System. Installation Limits Under Jurisdiction of Local Authority."

APPROVAL: Listed as control unit accessories when used in conjunction with listee's separately listed Models AM2020/AFP1010 (CSFM Listing No. 7165-0028:141 and 7170-0028:153), AFP-200, (CSFM Listing No. 7165-0028:164), AFP-300/400 (CSFM Listing No. 7165-0028:181 and 7170-0028:182) and NFS-640/640E (CSFM Listing No. 7165-0028:214 and 7170-0028:216) compatible fire alarm control units.

10-29-2002 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **OCTOBER 29, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager